EQUIP: ENV. INSPECTION OF TANKS (METRO, RCRA, PSAPCA)

ADDENDUM: 0800

DATE JANUARY 1995

ADDENDUM: 0800 PAGE: 1 of 7

FREQ	SKILL	JOB DESCRIPTION INSP. TANKS FOR LEAKS/TANK COND. (PSAPCA)			
DAILY	L6				
PROPERTY JOB NO.:	NO.: 65-0509 087352	95-001 (MET	RO)		
ABF 140	3-369	WEST	25,000	WASTE WATER	
ABF 141	3-369	WEST	25,000	WASTE WATER	
ABF 103	3-369	WEST	25,000	WASTE WATER	
ABF 104	3-369	WEST	25,000	WASTE WATER	
ABF 121	3-380	SOUTH	20,000	WASTE WATER	
ABF 122 ABF 112	3-380 3-369	SOUTH WEST	20,000 500	WASTE WATER HYDROGEN PEROXIDE	
	7/7/95	· · · · · · · · · · · · · · · · · · ·		7/5/95	7/6/95
TANK	FRIDAY	MONDAY	TUESDAY	WEDNESDAY	THURSDAY
ABF 140	TIES.		Holiday	me	MC
ABF 141	TAR			MC	me
ABF 103	THE STATE OF THE S			MC	me
ABF 104	***			me	me
ABF 121	TIB			MC	me
ABF 112	#6			MC	MC
	1 7	1			/ha

- 1. INSPECT EACH TANK LISTED ABOVE, AND ASSOCIATED PIPING AND PUMPS, DAILY. INSPECT FOR LEAKAGE OR DAMAGE. CHECK INTERSTITIAL SPACE MONITOR, IF TANK IS SO EQUIPPED, FOR LEAK INDICATION.
- 2. HAND SIGN INSPECTION SHEET

ABF 122

- 3. NOTE ANY REPAIRS NEEDED AND DATE REPORTED.
- 4. REQUEST A WORK CLASS 22 (PLANNED JOB) FOR ANY REPAIRS REQUIRED.
- 5. FILE THIS INSPECTION RECORD AT THE ENVIRONMENTAL OPERATIONS OFFICE.

>>>>>>>> End of Page 1

EQUIP: ENV. INSPECTION OF TANKS (METRO, RCRA, PSAPCA) DATE JANUARY 1995

PAGE : 2 of 7

PROPERTY NO.: 65-050995-001 (METRO)

JOB NO.: 087352

6. ENSURE STRIPPING TOWER IS CLEAR FROM OBSTRUCTIONS AND OPERATES. PROPERLY.

RETURN COMPLETED ADDENDUM TO YOUR SUPERVISOR.

DATE: 7-6-95 TIME: 2 hrs.

KEEP THIS AND ALL ENVIRONMENTAL PAPERWORK TOGETHER FOR FIVE (5) YEARS.

End of Page 2